

# **Nonmetallic Boxes**





Cat. No.	Volume (Cu. in.)	Width (in.)	Edge Height (in.)	Edge Width (in.)	Cable Entries	Use with		
2-3/4 in. Deep - 3-3/4 in. High – Device boxes								
WSW	18.0	2-1/4	_	_	4	Nonmetallic sheathed cable		
WSW-BX	18.0	2-1/4	5	4-1/4	4	AC90-Armoured cable		
WSW-N	18.0	2-1/4	<del>_</del>	<del>-</del>	4	Nonmetallic sheathed cable		
2-WSW	33.0	4	5	5-1/2	8	Nonmetallic sheathed cable		
3-WSW	48.0	5-3/4	5	7-1/2	12	Nonmetallic sheathed cable		
4-WSW	67.0	7-5/8	5	8-3/4	16	Nonmetallic sheathed cable		
WSW-FC	18.0	2-1/4	_	_	4	Nonmetallic sheathed cable		
2-3/4 in. Deep ·	2-3/4 in. Deep - 3-3/4 in. High - 4 in. Wide – Celling boxes							
WOCT	26.0	_	_	_	4	Nonmetallic sheathed cable		
WOCT-FC	26.0	_	5-1/4	_	4	Nonmetallic sheathed cable		
3 in. Deep - 4-7/8 in. High - 4-7/8 in. Wide – Oven and dryer								
WRD	61.0	_	6-7/8	6-7/8	4	Nonmetallic sheathed cable		



# **Nonmetallic Boxes**

### **Airtight Model**









F-WSW

**FWSWBX** 

2-FWSW

3-FWSW









4-FWSW

**FWOCT** 

**FWRD** 

WSW-P



Cat. No.	Volume (Cu. in.)	Width (in.)	Edge Height (in.)	Edge Width (in.)	Cable Entries	Use with	
2-3/4 in. Deep - Non-Gangable - 3-3/4 in. High – Device boxes							
F-WSW	18.0	2-1/4	_	_	4	Nonmetallic sheathed cable	
FWSWBX	18.0	2-1/4	5	4-1/4	4	AC90 – Armoured cable	
2-FWSW	33.0	4	5	5-1/2	8	Nonmetallic sheathed cable	
3-FWSW	48.0	5-3/4	5	7-1/2	12	Nonmetallic sheathed cable	
4-FWSW	67.0	7-5/8	5	8-3/4	16	Nonmetallic sheathed cable	
2-3/4 in. Deep - 3-3/4 in. High - 4 in. Wide – Celling boxes							
FWOCT	26.0	_	5-1/4	_	4	Nonmetallic sheathed cable	
3 in. Deep - 4-7/8 in. High - 4-7/8 in. Wide – Oven and dryer							
FWRD	61.0	_	6-7/8	6-7/8	4	Nonmetallic sheathed cable	

Cat. No.	Description
Partition	
WSW-P	Voltage partition – For 4-WSW and 4-FWSW only

Note: CEC 2012 rule 30-302: 4) Where the weight of a luminaire does not exceed 23 kg (50 lb.), the luminaire shall be permitted to be supported by a ceiling outlet box attached directly to the building structure or by a ceiling outlet box attached to a bar hanger. Requires that a ceiling-mounted luminaire weighing 23 kg or less be supported on a ceiling outlet box attached directly to the building structure. A bar hanger may also be used to attach a ceiling box to the building structure when the luminaire weighs 23 kg or less.





### **Nonmetallic Boxes**

#### **Fire Resistance Rating: 2 hours**







WSW-US

F-WSW-US

2WSW-US







2-FWSW-US

**WOCT-US** 

F-WOCT-US





Cat. No.	Volume (Cu. in.)	Width (in.)	Edge Height (in.)	Edge Width (in.)	Cable Entries	Use with	
2-3/4 in. Deep - Non-gangable - 3-3/4 in. High – Device boxes							
WSW-US	18.0	2-1/4	_	_	4	Nonmetallic sheathed cable	
F-WSW-US	18.0	2-1/4	_	_	4	Nonmetallic sheathed cable	
2WSW-US	33.0	4	5	5-1/2	8	Nonmetallic sheathed cable	
2-FWSW-US	33.0	4	5	5-1/2	8	Nonmetallic sheathed cable	
2-3/4 in. Deep - 3-3/4 in. High - 4 in. Wide – Ceiling boxes							
WOCT-US	26.0	_	_	_	4	Nonmetallic sheathed cable	
F-WOCT-US	26.0	<del>_</del>	_	_	4	Nonmetallic sheathed cable	