


LABEL: CSA ENCLOSURE
CAT.NO., & DATE CODE
RATING: 100AMP 600VAC 3PH
WIRE SIZE: #8-1/0 CU/AL



YMSSFC7050013
(Insulation 3 REQ'D.)

1-1/4, 1-1/2, 2, 2-1/2 KO. (QTY.3)
(1-3/4, 2, 2-1/2, 3" DIA.)

ZMSSFC7051518
(Block Ass'y. Left Centre)

ZMSSFC7051519
(Block Ass'y. Right Centre)

ZMS428HP3 (Hub Plate) ▲
YMS115HS1 (Hub Strap)
XNUT0001 (1/4-20 Wing Nut)
XMS616 (HUB GASKET) ▲
ALTERNATE: XMS459HP3

ZMSSFC7051337 (Body Assembly)

LABEL: Permanently Isolated Neutral Assy

LABEL: CSA ENCLOSURE, CAT.NO., & DATE CODE

ZMSSFC7051336 (Isolated Neutral Assembly)
XLW0011, X6071428 (Lockwasher & 10-32 Nut)

XMS6A (Jaw Shroud)
(2 REQ'D.)

ZMS111B (Block Assembly End) ▲
(2 REQ'D.)

XSCR039 (10-32 X 1-1/4 TYPE C)
(8 SCREWS REQ'D.)


YMS456BR (Bridge, 1-5/16" Height)

XSCR007 (10-32 X 1/4 TYPE C)
(4 SCREWS REQ'D.)


XMS114GL (Ground Lug #4-14)
XSCR002 (10-32 X 3/4 TYPE C)

NOTE: ADD ZMS7050916
(Sealing Ring Assy.)
& XMS46FD
(White Filler Disc)

0.590
0.500



SECTION THROUGH BOX



8.63 REF.

ZMS105B1 (Cover Assy.)

1/2" KO
(7/8" DIA.)

4.75
REF.

1-1/4, 1-1/2, 2, 2-1/2 KO.
(1-3/4, 2, 2-1/2, 3" DIA.)

C	DCT	CSA ISOLATED NEUTRAL CHANGES
B	FEB	DISCREPANCY WAS THROUGHT
A	MAR	29/01 INSULATION WAS DISCREPANCY
REV DATE CHANGE		
DO NOT SCALE		
SCALE: ALL DIMENSIONS IN INCH UNLESS NOTED		
DRW BY:	PJS	DESCRIPTION: 100A OVERHEAD METER SOCKET
APPD BY:	<i>krc</i>	PART NO. SFC703PW
		DWG. NO. SFC703PW

HE	
HYDEL ENTERPRISES DIVISION OF CRICA METALS INC. 208 GREAT GULF DRIVE, VAUGHAN	
REV. C	SHEET OF
DESCRIPTION: 100A OVERHEAD METER SOCKET	
PART NO. SFC703PW	
DWG. NO. SFC703PW	